



PRODUCT PERFORMANCE REPORT

Document ID 1522413316
 Issued on March 30th, 2018

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Hristov**
 Company **Cameo ltd**
 Project reference **Daikin FTXJ50MW/RXJ50M ? Emura**
 Project location **Bulgaria**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.087**
 Brand **DAIKIN**
 Range **RXJ**
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
 Product reference **RXJ50M / FTXJ50MS**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	63	dB(A)
Lw1 env	60	dB(A)
Bivalent Point		
Tbiv	-7	Â°C
COP @ Tbiv	2.47	
Ph TBiv	4.19	kW
General		
Mounting	Wall mounted	
MPS	230-1-50	
Refrigerant	R32	
Heating 14511		
Ph @+7	5.8	kW
COP @+7	3.65	
Heating Average Climate		
Pdesignh	4.6	kW
SCOP	4.28	
SCOP Class	A+	
Qhe	1505.0	kWh/annum
Poffc		
Poff	1.0	W
Psb		
Psb	1.0	W



PRODUCT PERFORMANCE REPORT

Document ID 1522413316
Issued on March 30th, 2018

FEATURE	VALUE	UNIT
Ptoc		
Pto	9.0	W
Seasonal Efficiency in Cooling		
Pdesignc	4.8	kW
SEER	7.02	
SEER Class	A++	
Qce	239.0	kWh/annum
Thermal		
EER @+35	3.35	
TOL Runing Test		
TOL	-15.0	Â°C
COP @ TOL	2.16	
Ph @ TOL	4.12	kW