



PRODUCT PERFORMANCE RATING

Document ID 040420201219-11481159

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.087

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

| | |
|-------------------|--|
| Product | Air Conditioners / Climatiseurs (AC) |
| Product type | Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible |
| Brand | DAIKIN |
| Range | RXA |
| Product référence | RXA25A / FTXA25AW |

This performance certificate is delivered for the following project:

| Project Name | Company | Project reference | Project location |
|----------------------------------|-----------|-------------------|------------------|
| Daikin FTXA25A_RXA25A Stylish | Cameo ltd | Hristov | Bulgaria |

| FEATURE | VALUE | UNIT |
|---|-------|------|
| STANDARD COOLING/COOLING PL COND A | | |
| Pc | 2.50 | kW |
| Pec | 0.56 | kW |
| EER | 4.46 | |



PRODUCT PERFORMANCE RATING

Document ID 040420201219-11481159

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.087

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

| FEATURE | VALUE | UNIT |
|-------------------------|-------|------|
| STANDARD HEATING | | |
| Ph | 2.80 | kW |
| Peh | 0.56 | kW |
| COP | 5.00 | |

| FEATURE | VALUE | UNIT |
|-----------------|-------|-------|
| ACOUSTIC | | |
| LwO env | 59 | dB(A) |
| LwI1 env | 57 | dB(A) |

| FEATURE | VALUE | UNIT |
|-------------------------|-------|------|
| COOLING PL CONDB | | |
| Pc @ 30°C | 1.84 | kW |
| EER @ 30°C | 6.79 | |



PRODUCT PERFORMANCE RATING

Document ID 040420201219-11481159

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.087

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

| FEATURE | VALUE | UNIT |
|-------------------------|-------|------|
| COOLING PL CONDC | | |
| Pc @ 25°C | 1.18 | kW |
| EER @ 25°C | 10.35 | |

| FEATURE | VALUE | UNIT |
|-------------------------|-------|------|
| COOLING PL CONDD | | |
| Pc @ 20°C | 1.29 | kW |
| EER @ 20°C | 16.30 | |

| FEATURE | VALUE | UNIT |
|---------------------------------------|--------|-----------|
| SEASONAL EFFICIENCY IN COOLING | | |
| Pdesignc | 2.50 | kW |
| SEER | 8.74 | |
| Qce | 101.00 | kWh/annum |
| SEER Class | A+++ | |



PRODUCT PERFORMANCE RATING

Document ID 040420201219-11481159

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.087

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

| FEATURE | VALUE | UNIT |
|-------------------------|-------|------|
| HEATING PL CONDA | | |
| Ph @ -7°C | 2.17 | kW |
| COP @ -7°C | 3.59 | |

| FEATURE | VALUE | UNIT |
|-------------------------|-------|------|
| HEATING PL CONDB | | |
| Ph @ +2°C | 1.32 | kW |
| COP @ 2°C | 5.22 | |

| FEATURE | VALUE | UNIT |
|-------------------------|-------|------|
| HEATING PL CONDC | | |
| Ph @ +7°C | 0.94 | kW |
| COP @ +7°C | 6.25 | |

| FEATURE | VALUE | UNIT |
|-------------------------|-------|------|
| HEATING PL CONDD | | |
| Ph @ +12°C | 1.10 | kW |
| COP @ +12°C | 8.02 | |



PRODUCT PERFORMANCE RATING

Document ID 040420201219-11481159

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.087

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

| FEATURE | VALUE | UNIT |
|--------------------------------|--------|-----------|
| HEATING AVERAGE CLIMATE | | |
| Pdesignh | 2.45 | kW |
| SCOP | 5.15 | |
| SCOP Class | A+++ | |
| Qhe | 666.00 | kWh/annum |

| FEATURE | VALUE | UNIT |
|-----------------------|-------|------|
| BIVALENT POINT | | |
| Tbiv | -7 | °C |
| COP @ Tbiv | 3.59 | |
| Ph TBiv | 2.17 | kW |

| FEATURE | VALUE | UNIT |
|------------------------|--------|------|
| TOL RUNING TEST | | |
| TOL | -15.00 | °C |
| COP @ TOL | 2.36 | |
| Ph @ TOL | 2.52 | kW |



PRODUCT PERFORMANCE RATING

Document ID 040420201219-11481159

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.087

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

| FEATURE | VALUE | UNIT |
|--------------|-------|------|
| POFFC | | |
| Poff | 0.50 | W |

| FEATURE | VALUE | UNIT |
|-------------|-------|------|
| PSBC | | |
| Psb | 0.50 | W |

| FEATURE | VALUE | UNIT |
|-------------|-------|------|
| PTOC | | |
| Pto | 7.00 | W |

| FEATURE | VALUE | UNIT |
|--------------|-------|------|
| POFFH | | |
| Poffh | 0.50 | W |

| FEATURE | VALUE | UNIT |
|-------------|-------|------|
| PSBH | | |
| Psbh | 0.50 | W |



PRODUCT PERFORMANCE RATING

Document ID 040420201219-11481159

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.087

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

| FEATURE | VALUE | UNIT |
|-------------|-------|------|
| PTOH | | |
| Ptoh | 13.00 | W |

| FEATURE | VALUE | UNIT |
|-------------------|--------------|------|
| GENERAL | | |
| Edibatec Export | false | |
| Capacity Control | variable | |
| Main Power Supply | 230-1-50 | |
| Refrigerant | R32 | |
| Refr. Line | 5 m | m |
| Mounting | Wall mounted | |