



PRODUCT PERFORMANCE REPORT

Document ID 1524638818
 Issued on April 25th, 2018

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Hristov**
 Company **Cameo ltd**
 Project reference **Fujitsu General AGHG09LVCA/AOHG09LVCA**
 ??????-??????
 Project location **Bulgaria**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.198**
 Brand **GENERAL**
 Range **AGH**L**
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
 Product reference **AOHG09LVCA / AGHG09LVCA**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	64	dB(A)
Lw11 env	55	dB(A)
Bivalent Point		
Tbiv	-7	Â°C
COP @ Tbiv	3.03	
Ph TBiv	2.57	kW
General		
Mounting	Floor standing	
MPS	230-1-50	
Refrigerant	R410A	
Refr. Line	5,0 m	m
Heating 14511		
Ph @+7	3.5	kW
COP @+7	4.43	
Heating Average Climate		
Pdesignh	2.9	kW
SCOP	4.2	
SCOP Class	A+	
Qhe	967.0	kWh/annum
Pck		
Pck	20.0	W



PRODUCT PERFORMANCE REPORT

Document ID 1524638818
 Issued on April 25th, 2018

FEATURE	VALUE	UNIT
Poffc		
Poff	9.0	W
Psb		
Psb	9.0	W
Ptoc		
Pto	10.0	W
Seasonal Efficiency in Cooling		
Pdesignc	2.6	kW
SEER	7.0	
SEER Class	A++	
Qce	130.0	kWh/annum
Thermal		
EER @+35	4.91	
TOL Runing Test		
TOL	-15.0	Â°C
COP @ TOL	2.58	
Ph @ TOL	2.03	kW