



# PRODUCT PERFORMANCE REPORT

Document ID 1524642569

Issued on April 25th, 2018

## PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Hristov**  
 Company **Cameo ltd**  
 Project reference **Fujitsu General AGHG12LVCA/AOHG12LVCA**  
 Project location **Bulgaria**

## PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.198**  
 Brand **GENERAL**  
 Range **AGH\*\*L**  
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**  
 Product reference **AOHG12LVCA / AGHG12LVCA**

### Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
<b>Acoustic</b>		
LwO env	64	dB(A)
Lw1 env	55	dB(A)
<b>Bivalent Point</b>		
Tbiv	-7	Â°C
COP @ Tbiv	2.47	
Ph TBiv	3.36	kW
<b>General</b>		
Mounting	Floor standing	
MPS	230-1-50	
Refrigerant	R410A	
Refr. Line	5,0 m	m
<b>Heating 14511</b>		
Ph @+7	4.5	kW
COP @+7	3.78	
<b>Heating Average Climate</b>		
Pdesignh	3.8	kW
SCOP	4.0	
SCOP Class	A+	
Qhe	1330.0	kWh/annum
<b>Pck</b>		
Pck	20.0	W
<b>Poffc</b>		



# PRODUCT PERFORMANCE REPORT

Document ID 1524642569

Issued on April 25th, 2018

FEATURE	VALUE	UNIT
Poff	9.0	W
<b>P<sub>sb</sub>c</b>		
Psb	9.0	W
<b>P<sub>to</sub>c</b>		
Pto	10.0	W
<b>Seasonal Efficiency in Cooling</b>		
Pdesignc	3.5	kW
SEER	6.5	
SEER Class	A++	
Qce	188.0	kWh/annum
<b>Thermal</b>		
EER @+35	3.72	
<b>TOL Runing Test</b>		
TOL	-15.0	Â°C
COP @ TOL	2.31	
Ph @ TOL	3.11	kW