



PRODUCT PERFORMANCE RATING

Document ID 050320191338

Issued on 3 May 2019

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.132

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	GENERAL
Range	ASH**L
Product référence	AOHG12LMCA / ASHG12LMCA

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
Hristov	Cameo ltd	Fujitsu General ASHG12LMCA- AOHG12LMCA	BG

FEATURE	VALUE	UNIT
GENERAL		
Refrigerant	R410A	
Main Power Supply	230-1-50	
Edibatec Export	false	
Refr. Line	5,0m	m
Mounting	Wall mounted	



PRODUCT PERFORMANCE RATING

Document ID 050320191338

Issued on 3 May 2019

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.132

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
THERMAL		
Pc	3.40	kW
Pec	0.97	kW
EER	3.50	

FEATURE	VALUE	UNIT
STANDARD HEATING		
Ph	4.00	kW
Peh	1.02	kW
COP	3.92	

FEATURE	VALUE	UNIT
ACOUSTIC		
LwO env	61	dB(A)
Lwl1 env	59	dB(A)



PRODUCT PERFORMANCE RATING

Document ID 050320191338

Issued on 3 May 2019

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.132

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
COOLING PL CONDB		
Pc @ 30°C	2.51	kW
EER @ 30°C	5.30	

FEATURE	VALUE	UNIT
COOLING PL CONDC		
Pc @ 25°C	1.61	kW
EER @ 25°C	9.23	

FEATURE	VALUE	UNIT
COOLING PL CONDD		
Pc @ 20°C	1.32	kW
EER @ 20°C	11.40	



PRODUCT PERFORMANCE RATING

Document ID 050320191338

Issued on 3 May 2019

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.132

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
SEASONAL EFFICIENCY IN COOLING		
Pdesignc	3.40	kW
SEER	7.00	
Qce	170.00	kWh/annum
SEER Class	A++	

FEATURE	VALUE	UNIT
HEATING PL CONDA		
Ph @ -7°C	3.10	kW
COP @ -7°C	2.43	

FEATURE	VALUE	UNIT
HEATING PL CONDB		
Ph @ +2°C	1.88	kW
COP @ 2°C	3.96	



PRODUCT PERFORMANCE RATING

Document ID 050320191338

Issued on 3 May 2019

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.132

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING PL CONDC		
Ph @ +7°C	1.51	kW
COP @ +7°C	5.74	

FEATURE	VALUE	UNIT
HEATING PL CONDD		
Ph @ +12°C	1.71	kW
COP @ +12°C	6.85	

FEATURE	VALUE	UNIT
HEATING AVERAGE CLIMATE		
Pdesignh	3.50	kW
SCOP	4.00	
SCOP Class	A+	
Qhe	1225.00	kWh/annum



PRODUCT PERFORMANCE RATING

Document ID 050320191338

Issued on 3 May 2019

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.132

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
BIVALENT POINT		
Tbiv	-7	°C
COP @ Tbiv	2.43	
Ph TBiv	3.10	kW

FEATURE	VALUE	UNIT
TOL RUNING TEST		
TOL	-15.00	°C
COP @ TOL	1.91	
Ph @ TOL	2.60	kW

FEATURE	VALUE	UNIT
HEATING WARMER CLIMATE		
SCOP	5.10	
Qhe	961.00	kWh/annum



PRODUCT PERFORMANCE RATING

Document ID 050320191338

Issued on 3 May 2019

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.132

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
AC_POFFC		
Poff	3.70	W

FEATURE	VALUE	UNIT
AC_PSBC (RT2012)		
Psb	3.70	W

FEATURE	VALUE	UNIT
AC_PTOC		
Pto	6.00	W

FEATURE	VALUE	UNIT
PCKC		
Pck	22.90	W