



# PRODUCT PERFORMANCE REPORT

Document ID 1522135430  
 Issued on March 27th, 2018

**PROJECT IDENTIFICATION** - This product performance report is delivered for:

Name **Hristov**  
 Company **Cameo ltd**  
 Project reference **Fujitsu General ASHG14KGTA/AOHG14KGCA**  
 Project location **Bulgaria**

**PRODUCT IDENTIFICATION**

Certification Diploma N° **94.01.198**  
 Brand **GENERAL**  
 Range **ASH\*\*K**  
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**  
 Product reference **AOHG14KGCA / ASHG14KGTA**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
<b>Acoustic</b>		
LwO env	65	dB(A)
Lw1 env	57	dB(A)
<b>Bivalent Point</b>		
Tbiv	-7	Â°C
COP @ Tbiv	2.69	
Ph TBiv	3.54	kW
<b>General</b>		
Mounting	Wall mounted	
MPS	230-1-50	
Refrigerant	R32	
Refr. Line	5,0 m	m
<b>Heating 14511</b>		
Ph @+7	5.4	kW
COP @+7	4.0	
<b>Heating Average Climate</b>		
Pdesignh	4.0	kW
SCOP	4.31	
SCOP Class	A+	
Qhe	1298.0	kWh/annum
<b>Poffc</b>		
Poff	1.0	W
<b>Psbcc</b>		



# PRODUCT PERFORMANCE REPORT

Document ID 1522135430  
Issued on March 27th, 2018

FEATURE	VALUE	UNIT
Psb	1.0	W
<b>Ptoc</b>		
Pto	6.0	W
<b>Seasonal Efficiency in Cooling</b>		
Pdesignc	4.2	kW
SEER	7.11	
SEER Class	A++	
Qce	207.0	kWh/annum
<b>Thermal</b>		
EER @+35	3.57	
<b>TOL Runing Test</b>		
TOL	-15.0	Â°C
COP @ TOL	2.53	
Ph @ TOL	3.52	kW