



PRODUCT PERFORMANCE REPORT

Document ID 1513514907

Issued on December 17th, 2017

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Hristov**
 Company **Cameo ltd**
 Project reference **Toshiba RAS-10PKVSG-E/10PAVSG-E SHORAI R32**
 Project location **Bulgaria**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.135**
 Brand **TOSHIBA**
 Range **Suzumi Plus**
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
 Product reference **RAS-10PAVSG-E/RAS-10PKVSG-E**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

| FEATURE | VALUE | UNIT |
|-----------------|----------|-------|
| Acoustic | | |
| LwO env | 61 | dB(A) |
| Lw1 env | 53 | dB(A) |
| Cooling | | |
| Pdesignc | 2.5 | kW |
| SEER | 6.9 | |
| SEER Class | A++ | |
| Qce | 127.0 | kWh/y |
| EER @+35 | 4.17 | |
| General | | |
| Mounting | HighWall | |
| MPS | 230-1-50 | |
| Refr. Line | 5.0 m | m |
| Refrigerant | R32 | |
| Heating | | |
| Pdesignh | 2.5 | kW |
| SCOP | 4.6 | |
| SCOP Class | A++ | |
| Qhe | 761.0 | kWh/y |
| Tbiv | -7 | C |
| Ph @Tbiv | 2.21 | kW |
| COP @Tbiv | 3.2 | |
| TOL | -15.0 | C |



PRODUCT PERFORMANCE REPORT

Document ID 1513514907

Issued on December 17th, 2017

| FEATURE | VALUE | UNIT |
|-----------------------------------|-------|------|
| Ph @ TOL | 1.45 | kW |
| COP @TOL | 2.25 | |
| Ph @+7 | 3.2 | kW |
| COP @+7 | 4.27 | |
| Power input in other modes | | |
| Poff | 1.0 | W |
| Psb | 1.0 | W |
| Pto | 30.0 | W |