



# PRODUCT PERFORMANCE RATING

Document ID 072420190901-9131763

Issued on 24 July 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 18.10.035**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	European Heat Pumps / Euro Heat Pump (Euro-HP)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	mitsubishi heavy industries thermal systems
Range	ZSX-W
Product référence	SRC20ZSX-W/SRK20ZSX-W

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
Hristov	Cameo ltd	Mitsubishi Heavy Industries SRK-SRC20ZSX-W	Bulgaria

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
Refrigerant	R32	
Main Power Supply	230-1-50	
Refr. Line	5m	m
Mounting	Wall mounted	



# PRODUCT PERFORMANCE RATING

Document ID 072420190901-9131763

Issued on 24 July 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 18.10.035**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>THERMAL</b>		
Pc	2.00	kW
Pec	0.31	kW
EER	6.45	

FEATURE	VALUE	UNIT
<b>STANDARD HEATING</b>		
Ph	2.70	kW
Peh	0.47	kW
COP	5.74	

FEATURE	VALUE	UNIT
<b>ACOUSTIC</b>		
LwO env	56	dB(A)
LwI1 env	53	dB(A)



# PRODUCT PERFORMANCE RATING

Document ID 072420190901-9131763

Issued on 24 July 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 18.10.035**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL CONDB</b>		
Pc @ 30°C	1.47	kW
EER @ 30°C	9.29	

FEATURE	VALUE	UNIT
<b>COOLING PL CONDC</b>		
Pc @ 25°C	1.25	kW
EER @ 25°C	13.90	

FEATURE	VALUE	UNIT
<b>COOLING PL CONDD</b>		
Pc @ 20°C	1.36	kW
EER @ 20°C	20.70	



# PRODUCT PERFORMANCE RATING

Document ID 072420190901-9131763

Issued on 24 July 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 18.10.035**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>SEASONAL EFFICIENCY IN COOLING</b>		
Pdesignc	2.00	kW
SEER	10.00	
Qce	70.00	kWh/annum
SEER Class	A+++	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDA</b>		
Ph @ -7°C	2.40	kW
COP @ -7°C	3.20	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDB</b>		
Ph @ +2°C	1.48	kW
COP @ 2°C	5.30	



# PRODUCT PERFORMANCE RATING

Document ID 072420190901-9131763

Issued on 24 July 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 18.10.035**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL CONDC</b>		
Ph @ +7°C	0.96	kW
COP @ +7°C	6.50	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDD</b>		
Ph @ +12°C	0.96	kW
COP @ +12°C	8.28	

FEATURE	VALUE	UNIT
<b>HEATING AVERAGE CLIMATE</b>		
Pdesignh	2.80	kW
SCOP	5.20	
SCOP Class	A+++	
Qhe	754.00	kWh/annum



# PRODUCT PERFORMANCE RATING

Document ID 072420190901-9131763

Issued on 24 July 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 18.10.035**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>BIVALENT POINT</b>		
Tbiv	-10	°C
COP @ Tbiv	2.79	
Ph TBiv	2.80	kW

FEATURE	VALUE	UNIT
<b>TOL RUNING TEST</b>		
TOL	-20.00	°C
COP @ TOL	2.33	
Ph @ TOL	2.12	kW

FEATURE	VALUE	UNIT
<b>AC_POFFC</b>		
Poff	4.00	W



# PRODUCT PERFORMANCE RATING

Document ID 072420190901-9131763

Issued on 24 July 2019

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 18.10.035**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>AC_PSBC (RT2012)</b>		
Psb	4.00	W

FEATURE	VALUE	UNIT
<b>AC_PTOC</b>		
Pto	11.00	W