



# PRODUCT PERFORMANCE RATING

Document ID 040420201228-11481162

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	DAIKIN
Range	RXA
Product référence	RXA35A / FTXA35AW

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
Daikin FTXA35A_RXA35A Stylish	Cameo ltd	Hristov	Bulgaria

FEATURE	VALUE	UNIT
<b>STANDARD COOLING/COOLING PL COND A</b>		
Pc	3.40	kW
Pec	0.78	kW
EER	4.37	



# PRODUCT PERFORMANCE RATING

Document ID 040420201228-11481162

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>STANDARD HEATING</b>		
Ph	4.00	kW
Peh	0.99	kW
COP	4.04	

FEATURE	VALUE	UNIT
<b>ACOUSTIC</b>		
LwO env	61	dB(A)
LwI1 env	60	dB(A)

FEATURE	VALUE	UNIT
<b>COOLING PL CONDB</b>		
Pc @ 30°C	2.51	kW
EER @ 30°C	6.28	



# PRODUCT PERFORMANCE RATING

Document ID 040420201228-11481162

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL CONDC</b>		
Pc @ 25°C	1.61	kW
EER @ 25°C	10.58	

FEATURE	VALUE	UNIT
<b>COOLING PL CONDD</b>		
Pc @ 20°C	1.33	kW
EER @ 20°C	16.21	

FEATURE	VALUE	UNIT
<b>SEASONAL EFFICIENCY IN COOLING</b>		
Pdesignc	3.40	kW
SEER	8.73	
Qce	137.00	kWh/annum
SEER Class	A+++	



# PRODUCT PERFORMANCE RATING

Document ID 040420201228-11481162

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL CONDA</b>		
Ph @ -7°C	2.21	kW
COP @ -7°C	3.58	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDB</b>		
Ph @ +2°C	1.35	kW
COP @ 2°C	5.19	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDC</b>		
Ph @ +7°C	0.94	kW
COP @ +7°C	6.19	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDD</b>		
Ph @ +12°C	1.10	kW
COP @ +12°C	7.97	



# PRODUCT PERFORMANCE RATING

Document ID 040420201228-11481162

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING AVERAGE CLIMATE</b>		
Pdesignh	2.50	kW
SCOP	5.15	
SCOP Class	A+++	
Qhe	680.00	kWh/annum

FEATURE	VALUE	UNIT
<b>BIVALENT POINT</b>		
Tbiv	-7	°C
COP @ Tbiv	3.58	
Ph TBiv	2.21	kW

FEATURE	VALUE	UNIT
<b>TOL RUNING TEST</b>		
TOL	-15.00	°C
COP @ TOL	2.30	
Ph @ TOL	2.62	kW



# PRODUCT PERFORMANCE RATING

Document ID 040420201228-11481162

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>POFFC</b>		
Poff	0.50	W

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psb	0.50	W

FEATURE	VALUE	UNIT
<b>PTOC</b>		
Pto	7.00	W

FEATURE	VALUE	UNIT
<b>POFFH</b>		
Poffh	0.50	W

FEATURE	VALUE	UNIT
<b>PSBH</b>		
Psbh	0.50	W



# PRODUCT PERFORMANCE RATING

Document ID 040420201228-11481162

Issued on 4 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 94.01.087**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>PTOH</b>		
Ptoh	13.00	W

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
Edibatec Export	false	
Capacity Control	variable	
Main Power Supply	230-1-50	
Refrigerant	R32	
Refr. Line	5 m	m
Mounting	Wall mounted	