



# PRODUCT PERFORMANCE REPORT

Document ID 1522403555  
 Issued on March 30th, 2018

**PROJECT IDENTIFICATION** - This product performance report is delivered for:

Name **Hristov**  
 Company **Cameo ltd**  
 Project reference **Daikin FTXP50L/RXP50L Comfora**  
 Project location **Bulgaria**

**PRODUCT IDENTIFICATION**

Certification Diploma N° **94.01.087**  
 Brand **DAIKIN**  
 Range **RXP**  
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**  
 Product reference **RXP50L / FTXP50L**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
<b>Acoustic</b>		
LwO env	61	dB(A)
Lw1 env	59	dB(A)
<b>Bivalent Point</b>		
Tbiv	-7	Å°C
COP @ Tbiv	2.29	
Ph TBiv	3.99	kW
<b>General</b>		
Mounting	Wall mounted	
MPS	230-1-50	
Refrigerant	R-32	
Refr. Line	5 m	m
<b>Heating 14511</b>		
Ph @+7	6.0	kW
COP @+7	3.8	
<b>Heating Average Climate</b>		
Pdesignh	4.6	kW
SCOP	4.1	
SCOP Class	A+	
Qhe	1571.0	kWh/annum
<b>Poffc</b>		
Poff	1.0	W
<b>Psbcb</b>		



# PRODUCT PERFORMANCE REPORT

Document ID 1522403555  
Issued on March 30th, 2018

FEATURE	VALUE	UNIT
Psb	1.0	W
<b>Ptoc</b>		
Pto	12.0	W
<b>Seasonal Efficiency in Cooling</b>		
Pdesignc	5.0	kW
SEER	6.72	
SEER Class	A++	
Qce	260.0	kWh/annum
<b>Thermal</b>		
EER @+35	3.61	
<b>TOL Runing Test</b>		
TOL	-15.0	Â°C
COP @ TOL	2.06	
Ph @ TOL	4.2	kW