



PRODUCT PERFORMANCE RATING

Document ID 022820200935-10848470

Issued on 28 February 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	GENERAL
Range	ASH**K
Product référence	AOHG14KETA/ASHG14KETA

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
Hristov	Cameo ltd	General Fujitsu ASHG14KETA_AOHG14KE TA	Bulgaria

FEATURE	VALUE	UNIT
STANDARD COOLING/COOLING PL COND A		
Pc	4.20	kW
Pec	1.22	kW
EER	3.44	



PRODUCT PERFORMANCE RATING

Document ID 022820200935-10848470

Issued on 28 February 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
STANDARD HEATING		
Ph	5.40	kW
Peh	1.41	kW
COP	3.83	

FEATURE	VALUE	UNIT
ACOUSTIC		
LwO env	65	dB(A)
Lwl env	57	dB(A)

FEATURE	VALUE	UNIT
COOLING PL CONDB		
Pc @ 30°C	3.09	kW
EER @ 30°C	5.10	



PRODUCT PERFORMANCE RATING

Document ID 022820200935-10848470

Issued on 28 February 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
COOLING PL CONDC		
Pc @ 25°C	1.99	kW
EER @ 25°C	8.75	

FEATURE	VALUE	UNIT
COOLING PL CONDD		
Pc @ 20°C	1.21	kW
EER @ 20°C	12.20	

FEATURE	VALUE	UNIT
SEASONAL EFFICIENCY IN COOLING		
Pdesignnc	4.20	kW
SEER	6.90	
Qce	213.00	kWh/annum
SEER Class	A++	



PRODUCT PERFORMANCE RATING

Document ID 022820200935-10848470

Issued on 28 February 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING PL CONDA		
Ph @ -7°C	3.54	kW
COP @ -7°C	2.45	

FEATURE	VALUE	UNIT
HEATING PL CONDB		
Ph @ +2°C	2.15	kW
COP @ 2°C	3.97	

FEATURE	VALUE	UNIT
HEATING PL CONDC		
Ph @ +7°C	1.38	kW
COP @ +7°C	5.81	

FEATURE	VALUE	UNIT
HEATING PL CONDD		
Ph @ +12°C	0.96	kW
COP @ +12°C	6.50	



PRODUCT PERFORMANCE RATING

Document ID 022820200935-10848470

Issued on 28 February 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING AVERAGE CLIMATE		
Pdesignh	4.00	kW
SCOP	4.10	
SCOP Class	A+	
Qhe	1367.00	kWh/annum

FEATURE	VALUE	UNIT
BIVALENT POINT		
Tbiv	-7	°C
COP @ Tbiv	2.45	
Ph TBiv	3.54	kW

FEATURE	VALUE	UNIT
TOL RUNING TEST		
TOL	-15.00	°C
COP @ TOL	2.50	
Ph @ TOL	3.33	kW



PRODUCT PERFORMANCE RATING

Document ID 022820200935-10848470

Issued on 28 February 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 94.01.198

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
POFFC		
Poff	5.00	W

FEATURE	VALUE	UNIT
PSBC		
Psb	5.00	W

FEATURE	VALUE	UNIT
PTOC		
Pto	1.00	W

FEATURE	VALUE	UNIT
GENERAL		
Main Power Supply	230-1-50	
Refrigerant	R32	
Refr. Line	5,0 m	m
Mounting	Wall mounted	