



PRODUCT PERFORMANCE REPORT

Document ID 1521280324
 Issued on March 17th, 2018

PROJECT IDENTIFICATION - This product performance report is delivered for:

Name **Hristov**
 Company **Cameo ltd**
 Project reference **Fujitsu General ASHG09KGTA/AOHG09KGCA**
 Project location **Bulgaria**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.198**
 Brand **GENERAL**
 Range **ASH**K**
 Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
 Product reference **AOHG09KGCA / ASHG09KGTA**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	61	dB(A)
Lw1 env	55	dB(A)
Bivalent Point		
Tbiv	-7	Â°C
COP @ Tbiv	3.14	
Ph TBiv	2.12	kW
General		
Mounting	Wall mounted	
MPS	230-1-50	
Refrigerant	R32	
Refr. Line	5,0 m	m
Heating 14511		
Ph @+7	2.8	kW
COP @+7	5.0	
Heating Average Climate		
Pdesignh	2.4	kW
SCOP	5.11	
SCOP Class	A+++	
Qhe	658.0	kWh/annum
Poffc		
Poff	1.0	W
Psbcc		



PRODUCT PERFORMANCE REPORT

Document ID 1521280324
Issued on March 17th, 2018

FEATURE	VALUE	UNIT
Psb	1.0	W
Ptoc		
Pto	5.0	W
Seasonal Efficiency in Cooling		
Pdesignc	2.8	kW
SEER	8.52	
SEER Class	A+++	
Qce	103.0	kWh/annum
Thermal		
EER @+35	4.5	
TOL Runing Test		
TOL	-15.0	Â°C
COP @ TOL	2.3	
Ph @ TOL	1.99	kW