



PRODUCT PERFORMANCE RATING

Document ID 012320211013-18972959

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.279

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	mitsubishi heavy industries thermal systems
Range	ZS-W
Product référence	SRC20ZS-W/SRK20ZS-W

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
Mitsubishi Heavy Industries SRK_SRC 20 ZS-W	Cameo ltd	Mitsubishi Heavy Industries	Bulgaria

FEATURE	VALUE	UNIT
STANDARD COOLING/COOLING PL COND A		
Pc	2.00	kW
Pec	0.44	kW
EER	4.55	



PRODUCT PERFORMANCE RATING

Document ID 012320211013-18972959

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.279

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
STANDARD HEATING		
Ph	2.70	kW
Peh	0.59	kW
COP	4.58	

FEATURE	VALUE	UNIT
ACOUSTIC		
LwO env	56	dB(A)
LwI1 env	48	dB(A)

FEATURE	VALUE	UNIT
COOLING PL CONDB		
Pc @ 30°C	1.40	kW
EER @ 30°C	6.80	



PRODUCT PERFORMANCE RATING

Document ID 012320211013-18972959

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.279

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
COOLING PL CONDC		
Pc @ 25°C	1.00	kW
EER @ 25°C	11.80	

FEATURE	VALUE	UNIT
COOLING PL CONDD		
Pc @ 20°C	1.00	kW
EER @ 20°C	18.20	

FEATURE	VALUE	UNIT
SEASONAL EFFICIENCY IN COOLING		
Pdesignc	2.00	kW
SEER	8.50	
Qce	83.00	kWh/annum
SEER Class	A+++	



PRODUCT PERFORMANCE RATING

Document ID 012320211013-18972959

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.279

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING PL CONDA		
Ph @ -7°C	2.40	kW
COP @ -7°C	2.50	

FEATURE	VALUE	UNIT
HEATING PL CONDB		
Ph @ +2°C	1.40	kW
COP @ 2°C	4.70	

FEATURE	VALUE	UNIT
HEATING PL CONDC		
Ph @ +7°C	0.95	kW
COP @ +7°C	6.24	

FEATURE	VALUE	UNIT
HEATING PL CONDD		
Ph @ +12°C	1.10	kW
COP @ +12°C	7.80	



PRODUCT PERFORMANCE RATING

Document ID 012320211013-18972959

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.279

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING AVERAGE CLIMATE		
Pdesignh	2.60	kW
SCOP	4.60	
SCOP Class	A++	
Qhe	793.00	kWh/annum

FEATURE	VALUE	UNIT
BIVALENT POINT		
Tbiv	-10	°C
COP @ Tbiv	2.20	
Ph TBiv	2.60	kW

FEATURE	VALUE	UNIT
TOL RUNING TEST		
TOL	-15.00	°C
COP @ TOL	2.05	
Ph @ TOL	2.10	kW



PRODUCT PERFORMANCE RATING

Document ID 012320211013-18972959

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.279

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
POFFC		
Poff	4.00	W

FEATURE	VALUE	UNIT
PSBC		
Psb	4.00	W

FEATURE	VALUE	UNIT
PTOC		
Pto	10.00	W

FEATURE	VALUE	UNIT
GENERAL		
Capacity Control	Variable	
Main Power Supply	230-1-50	
Refrigerant	R32	
Refr. Line	5 m	m
Mounting	Wall mounted	



PRODUCT PERFORMANCE RATING

Document ID 012320211013-18972959

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 17.02.279

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
EDIBATEC_H		
Nb Taval Chauffage	1	
Nb Tamont Chauffage	1	

FEATURE	VALUE	UNIT
EDIBATEC_C		
Nb Taval Froid	1	
Nb Tamont Froid	1	