



# PRODUCT PERFORMANCE RATING

Document ID 012320210953-18972962

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	mitsubishi heavy industries thermal systems
Range	ZS-W
Product référence	SRC25ZS-W/SRK25ZS-W

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
Mitsubishi Heavy Industries SRK_SRC 25 ZS-W	Cameo ltd	Mitsubishi Heavy Industries	Bulgaria

FEATURE	VALUE	UNIT
<b>STANDARD COOLING/COOLING PL COND A</b>		
Pc	2.50	kW
Pec	0.62	kW
EER	4.03	



# PRODUCT PERFORMANCE RATING

Document ID 012320210953-18972962

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>STANDARD HEATING</b>		
Ph	3.20	kW
Peh	0.74	kW
COP	4.32	

FEATURE	VALUE	UNIT
<b>ACOUSTIC</b>		
LwO env	56	dB(A)
Lwl env	50	dB(A)

FEATURE	VALUE	UNIT
<b>COOLING PL CONDB</b>		
Pc @ 30°C	1.80	kW
EER @ 30°C	6.45	



# PRODUCT PERFORMANCE RATING

Document ID 012320210953-18972962

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>COOLING PL CONDC</b>		
Pc @ 25°C	1.11	kW
EER @ 25°C	11.80	

FEATURE	VALUE	UNIT
<b>COOLING PL CONDD</b>		
Pc @ 20°C	1.10	kW
EER @ 20°C	18.20	

FEATURE	VALUE	UNIT
<b>SEASONAL EFFICIENCY IN COOLING</b>		
Pdesignc	2.50	kW
SEER	8.50	
Qce	103.00	kWh/annum
SEER Class	A+++	



# PRODUCT PERFORMANCE RATING

Document ID 012320210953-18972962

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING PL CONDA</b>		
Ph @ -7°C	2.40	kW
COP @ -7°C	2.50	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDB</b>		
Ph @ +2°C	1.40	kW
COP @ 2°C	4.92	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDC</b>		
Ph @ +7°C	0.95	kW
COP @ +7°C	6.15	

FEATURE	VALUE	UNIT
<b>HEATING PL CONDD</b>		
Ph @ +12°C	1.10	kW
COP @ +12°C	7.86	



# PRODUCT PERFORMANCE RATING

Document ID 012320210953-18972962

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>HEATING AVERAGE CLIMATE</b>		
Pdesignh	2.70	kW
SCOP	4.70	
SCOP Class	A++	
Qhe	804.00	kWh/annum

FEATURE	VALUE	UNIT
<b>BIVALENT POINT</b>		
Tbiv	-10	°C
COP @ Tbiv	2.40	
Ph TBiv	2.70	kW

FEATURE	VALUE	UNIT
<b>TOL RUNING TEST</b>		
TOL	-15.00	°C
COP @ TOL	2.10	
Ph @ TOL	2.30	kW



# PRODUCT PERFORMANCE RATING

Document ID 012320210953-18972962

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>POFFC</b>		
Poff	4.00	W

FEATURE	VALUE	UNIT
<b>PSBC</b>		
Psb	4.00	W

FEATURE	VALUE	UNIT
<b>PTOC</b>		
Pto	10.00	W

FEATURE	VALUE	UNIT
<b>GENERAL</b>		
Capacity Control	Variable	
Main Power Supply	230-1-50	
Refrigerant	R32	
Refr. Line	5 m	m
Mounting	Wall mounted	



# PRODUCT PERFORMANCE RATING

Document ID 012320210953-18972962

Issued on 23 January 2021

This product is certified by Eurovent Certita Certification as mentioned on

**Certificate N° 17.02.279**

This document is valid at the date of issue - **Check the current validity on [www.eurovent-certification.com](http://www.eurovent-certification.com)**

FEATURE	VALUE	UNIT
<b>EDIBATEC_H</b>		
Nb Taval Chauffage	1	
Nb Tamont Chauffage	1	

FEATURE	VALUE	UNIT
<b>EDIBATEC_C</b>		
Nb Taval Froid	1	
Nb Tamont Froid	1	