



PRODUCT PERFORMANCE RATING

Document ID 040620201738-11482193

Issued on 6 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 18.06.007

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner below 12 kW/ air-cooled/ split/ reversible
Brand	TOSHIBA
Range	SHORAI Edge
Product référence	RAS-13J2AVSG-E/RAS-B13J2KVSG-E

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
Toshiba RAS-B13J2KVSG-E_J2AVSG-E SHORAI Edge	Cameo ltd	Hristov	Bulgaria

FEATURE	VALUE	UNIT
STANDARD COOLING/COOLING PL COND A		
Pc	3.50	kW
Pec	0.90	kW
EER	3.89	



PRODUCT PERFORMANCE RATING

Document ID 040620201738-11482193

Issued on 6 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 18.06.007

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
STANDARD HEATING		
Ph	4.20	kW
Peh	1.08	kW
COP	3.89	

FEATURE	VALUE	UNIT
ACOUSTIC		
LwO env	59	dB(A)
LwI1 env	56	dB(A)

FEATURE	VALUE	UNIT
COOLING PL CONDB		
Pc @ 30°C	2.58	kW
EER @ 30°C	7.85	



PRODUCT PERFORMANCE RATING

Document ID 040620201738-11482193

Issued on 6 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 18.06.007

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
COOLING PL CONDC		
Pc @ 25°C	1.66	kW
EER @ 25°C	10.60	

FEATURE	VALUE	UNIT
COOLING PL CONDD		
Pc @ 20°C	1.00	kW
EER @ 20°C	12.65	

FEATURE	VALUE	UNIT
SEASONAL EFFICIENCY IN COOLING		
Pdesignc	3.50	kW
SEER	8.60	
Qce	142.00	kWh/annum
SEER Class	A+++	



PRODUCT PERFORMANCE RATING

Document ID 040620201738-11482193

Issued on 6 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 18.06.007

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING PL CONDA		
Ph @ -7°C	2.83	kW
COP @ -7°C	3.20	

FEATURE	VALUE	UNIT
HEATING PL CONDB		
Ph @ +2°C	1.72	kW
COP @ 2°C	4.95	

FEATURE	VALUE	UNIT
HEATING PL CONDC		
Ph @ +7°C	1.11	kW
COP @ +7°C	7.05	

FEATURE	VALUE	UNIT
HEATING PL CONDD		
Ph @ +12°C	1.14	kW
COP @ +12°C	9.05	



PRODUCT PERFORMANCE RATING

Document ID 040620201738-11482193

Issued on 6 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 18.06.007

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING AVERAGE CLIMATE		
Pdesignh	3.20	kW
SCOP	5.10	
SCOP Class	A+++	
Qhe	878.00	kWh/annum

FEATURE	VALUE	UNIT
BIVALENT POINT		
Tbiv	-7	°C
COP @ Tbiv	3.20	
Ph TBiv	2.83	kW

FEATURE	VALUE	UNIT
TOL RUNING TEST		
TOL	-15.00	°C
COP @ TOL	2.50	
Ph @ TOL	2.21	kW



PRODUCT PERFORMANCE RATING

Document ID 040620201738-11482193

Issued on 6 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 18.06.007

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
POFFC		
Poff	1.00	W

FEATURE	VALUE	UNIT
PSBC		
Psb	1.00	W

FEATURE	VALUE	UNIT
PTOC		
Pto	24.00	W



PRODUCT PERFORMANCE RATING

Document ID 040620201738-11482193

Issued on 6 April 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 18.06.007

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
GENERAL		
Edibatec Export	true	
Capacity Control	Variable	
Main Power Supply	230-1-50	
Refrigerant	R32	
Refr. Line	5.0 m	m
Mounting	Wall mounted	